



Contact: Kirsty Brown
Telephone: (08) 8226 7100
Email: kirsty.brown@health.sa.gov.au

Public Health Services

Citi Centre Building
11 Hindmarsh Square
Adelaide SA 5000
PO Box 6
Rundle Mall SA 5000
DX 243
Tel 08 8226 7100
Fax 08 8226 7102
ABN 97 643 356 590
www.health.sa.gov.au

Our reference: WWP-29/16

5 April 2016

Adam Prescott
OzziKleen Waste Water Management
59 Industrial Ave
KUNDA PARK QLD 4556

Dear Adam

RE: PRODUCT APPROVAL FOR THE OZZIKLEEN ST10/ST10A 4500L SEPTIC TANK

I refer to your application seeking approval for the above products.

I advise that, pursuant to South Australian Public Health (Wastewater) Regulations 2013, an approval is issued for marketing, sale and installation of the Ozzikleen ST10/ST10A 4500L septic tank in South Australia, subject to the following conditions:

1. The approved system consists of the following components:
 - 1.1. A 4500L polyethylene vertical septic tank with either one chamber (ST10) or two chambers (ST10A) with an overall height of 2300mm, manufactured in accordance with AS/NZS 1546.1.
2. Compliance is required with:
 - 2.1. The plans and specifications as submitted.
 - 2.2. The manufacturer/suppliers' instructions and recommendations.
 - 2.3. All relevant standards and codes.
 - 2.4. Conditions of this approval.
3. The manufacturer shall provide the following information to the owner of the premises at which the system is installed:
 - 3.1. Copies of the Installation Manual for the system.
 - 3.2. A copy of any additional SA Department for Health and Ageing guidelines and requirements including a copy of the section of this approval titled 'Installation, operation and maintenance requirements of the Ozzikleen ST10/ST10A 4500L Septic Tank'.
 - 3.3. Instructions informing persons installing, operating and or maintaining the septic tank of their obligations with regard to the 'Confined Space' requirements pursuant to the Work Health and Safety Regulations 2012.

4. Other requirements for the approved product are as follows:
 - 4.1. Lids and access openings are to be fitted so as to be childproof.
 - 4.2. Maximum burial depth must be 2400mm.
5. The DHA reserves the right to conduct an inspection on a completed unit to establish compliance with the submitted plans and the conditions of this approval.
6. Modification of the design of the system or any of its associated components requires approval by the DHA.
7. This approval is not to be used for any advertising purposes and is not transferable.
8. Pursuant to the South Australia Public Health (Wastewater) Regulations 2016, an approval is granted for a period of five years from the date of this approval. This approval will lapse unless renewed by the submission of an application and grant of an approval from the DHA prior to the expiry date.
9. Pursuant to the South Australian Public Health (Wastewater) Regulations 2013, the DHA reserves the right to vary any or all of the approval conditions, and require the repair, replacement, rectification, or alteration of the system or any part thereof should at any time:
 - 9.1. The system or a component thereof not be manufactured, maintained and/or operated in accordance with the approval conditions; or
 - 9.2. The system is defective and not able to perform the function for which the approval was issued.



Approved by: (Mr Anthony Farror) Date: 5 April 2016

Manager, Wastewater Management Section
Delegate of the Minister for Health and Ageing


References: - All information provided by Ozzikleen Waste Water Management

Attachments:


- Ozzikleen '4500L Septic tank, ST10' drawing.
- Ozzikleen '4500L Septic tank, ST10A' drawing.

INSTALLATION, OPERATION AND MAINTENANCE REQUIREMENTS OF THE OZZIKLEEN ST10 & S10A 4500L SEPTIC TANK

- Note 1:** All installations of the OzziKleen ST10/ST10A 4500L septic tank are to be subject to individual application and fee to the relevant approving authority for assessment of prevailing site conditions to determine the system installation requirements in addition to the requirements of this approval. The relevant authority reserves the right to require further testing and/or information to be carried out/supplied in order to assess an application of this nature.
- Note 2:** A licensed plumber must carry out the installation of the system. Installation must be in accordance with AS/NZS 3500, the product and installation approval conditions, manufacturers' requirements and any other specific requirements by the relevant authority.
- Note 3:** The effluent disposal site is required to be set up prior to use of the system and occupation of the premises. The effluent disposal area must be designed and installed in accordance with *the Onsite Wastewater Systems Code*.
- Note 4:** The system, once installed, must be maintained in a fully operational and sanitary state at all times by the user/owner of the system in accordance with the product and installation approval conditions, manufacturers' requirements and any other specific requirements by the relevant authority.
- Note 5:** Vehicular traffic is to be excluded from the area around the unit and the effluent disposal site.
- Note 6:** Sludge from the system is to be taken away by an EPA licensed operator to an approved site and in accordance with the SA Biosolids Guidelines.
- Note 7:** The relevant authority reserves the right to exclude connection of this product to a Community Wastewater Management System.




ST10A - ELEVATION




ST10A - PLAN

- NOTES:
1. Ozzi Klean POLYETHYLENE TANK IS CERTIFIED TO AS/NZS 1546.1.
 2. PLEASE SEE INSTALLATION GUIDELINES FOR MINIMUM REQUIREMENTS.
 3. PLEASE CONFIRM INVERT LEVELS WHEN ORDERING.

		Suncoast Waste Water Management	
59 INDUSTRIAL AVE KUNDA PARK QLD 4556 Ph: +61 7 5459 4900 Fax: +61 7 5456 4677 www.ozziclean.com		CLIENT GENERAL	DESIGN AP
PROJECT 4,500L SEPTIC TANK - ST10A		DRAWN YH	DATE 02/02/16
TITLE GENERAL LAYOUT		CHKD AP	SCALE NTS
DWG NO. CD-ST10A-H10			
DATE 02/02/16	DESCRIPTION GENERAL REVISION	REV. 1	BY YH



ST10 - ELEVATION



ST10 - PLAN

NOTES:
 1. Ozzi Kleen POLYETHYLENE TANK IS CERTIFIED TO AS/NZS 1546.1.
 2. PLEASE SEE INSTALLATION GUIDELINES FOR MINIMUM REQUIREMENTS.
 3. PLEASE CONFIRM INVERT LEVELS WHEN ORDERING.

59 INDUSTRIAL AVE KUNDA PARK QLD 4556 PH: +61 7 5459 4900 PAX: +61 7 5456 4677 www.ozzicleen.com		CLIENT		GENERAL		DESIGN	AP
		PROJECT		4,500L SEPTIC TANK - ST10		DRAWN	YH
		TITLE		GENERAL LAYOUT		CHKD	AP
		DWG NO.		GD-ST10-H10		DATE	02/02/16
						SCALE	NTS
OZZIKLEEN Water & Waste Water		Suncoast Waste Water Management					
02/02/16	GENERAL REVISION	1	YH	BY			
DATE	DESCRIPTION	REV.					